TAMIL NADU FIRE AND RESCUE SERVICES

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and

Tamil Nadu Fire Service Rule 1990 - Appendix-III)

Licence No: 6782/FL/NMSB/2026

District Office,

Fire and Rescue Service,

ChennaiDistrict.

Dated: 22/01/2026

ISSUE OF FIRE LICENSE

Ref: (1)Letter no: 355721 from the M/s.Suaj Chemicals Dated: 21/12/2025

****

The Fire License is hereby granted under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for other **To Run Sales House Cleaning Items** in the name style **M/s.Suraj Chemicals, No:29/42, Kutty Street, Chennai – 600 001, Consisting of G+1 Floor (Running Ground Floor Only)** with the height of **10 Meters** and **Plot Area:55.74 Sq.mt, total built-up area in 165.31 Sq.mt** within the jurisdiction of Chennai Corporation based on the inspection was done by **Thiru R.Suresh Station Officer Transport Esplanade Fire And Rescue Station on 05.01.2026** Subject to the condition noted thereon and such other conditions as may be prescribed. This license is valid for **THREE YEARS** from the date of issue.

CONDITIONS

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. All Staff should be trained in preliminary firefighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. Mock drillshouldbe periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Do's & Don'ts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided.
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained. As per IS 1646 : 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.

Signature valid

Signed by: Mr.C.ROBIN CASTRO
DO Chennai North
Northern Region - District Officer,
Home Department
Date:22-Jan-2026 11:43:31

To:

M/s.Suraj Chemicals,

No:29/42, Kutty Street,

Chennai – 600 001.